

Village of Lithopolis Drinking Water Consumer Confidence Report For 2022

The Village of Lithopolis has prepared the following report to provide information to you, the consumer, on the quality of our drinking water. Included within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water system contacts.

Source Water Information

The Village of Lithopolis community public water system serves over 1,700 people. This system currently operates two wells that pump from a sand and gravel aquifer (water-rich zone) which is covered by approximately 10 feet of low-permeability material. This thin layer provides minimal protection from contamination. Depth to water in this aquifer is less than 15 feet below the ground surface.

In 2003 Ohio EPA completed a study of the Village of Lithopolis' source of drinking water to identify potential contaminant sources and provide guidance on protecting the drinking water source. According to this study, the aquifer has a high susceptibility to contamination. This determination is based on the following:

1. The presence of a relatively thin protective layer of clay overlying the aquifer;
2. The shallow depth (less than 15 feet below ground surface) of the aquifer;
3. The presence of significant potential contaminant sources in the protection area.

Since 2003, the environment surrounding the well field has not changed. This assessment reflects current conditions. There is currently no evidence to suggest that the Village's ground water has been impacted by any significant levels of chemical contaminants from human activities.

However, this susceptibility means that under currently existing conditions, the likelihood of the aquifer becoming contaminated is relatively high. OEPA has determined that this likelihood can be minimized by implementing appropriate protective measures. To minimize this risk, the Village of Lithopolis continues to participate in the Fairfield County Regional Drinking Water Source Protection Plan and has passed a Well Head Protection Ordinance which places restrictions on activities within the area of the production wells.

Beginning in late 2022 and concluding in 2023, the Village performed comprehensive maintenance on each of the three wells providing water to the Village Water Treatment Plant. Three pumps were removed and replaced, discharge pipes were replaced, wells were cleaned and sterilized.

More information about the source water assessment, the Fairfield County Regional Drinking Water Source Protection Plan, or what consumers can do to help protect the aquifer is available by contacting Mayor Sandine at the Village office at 614-837-2031.

The Wellhead Protection Ordinance (19-11) can be found on the Village Web Page at <http://www.lithopolis.org/wp-content/uploads/2017/02/Ord.-19-11.pdf>.

The Village also maintains an emergency connection to the Canal Winchester water system which has not yet been used to supply water to Lithopolis residents.

What are sources of contamination to drinking water?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; (B) Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (C) Pesticides and herbicides, which may come

from a variety of sources such as agriculture, urban storm water runoff, and residential uses; (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; (E) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Federal Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

Who needs to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

About your drinking water.

The EPA requires regular sampling to ensure drinking water safety. The Village of Lithopolis conducted sampling for ***Nitrate, bacteria, Volatile Organic Chemicals, Disinfection Byproducts, and Lead and Copper*** during **2022**. Samples were collected for a total of **36** different contaminants most of which were not detected in the Lithopolis water supply. The Ohio EPA requires us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, are more than one year old.

Monitoring & Reporting Violations & Enforcement Actions

2017 – In the 2017 CCR, in the Table of Detected Contaminants, we listed the incorrect 90th percentile value for copper and included several contaminants that were not found in our drinking water with the most recent samples.

2018 – In the 2018 CCR, in the Table of Detected Contaminants, we listed incorrect MCLG values for barium and fluoride, the incorrect MCL value for fluoride, and failed to report the sample year for TTHM.

2021 – In the 2021 CCR, we failed to include the status of our License to Operate and the required information regarding the availability and level of susceptibility of the Source Water Assessment Report. In our Table of Detected Contaminants, we failed to list results for nitrate, barium, fluoride, gross alpha, and did not list the units for chlorine.

Corrected versions of the Village of Lithopolis CCR for the above years will be posted to the appropriate web addresses.

2017 Corrected CCR: <https://www.lithopolis.org/wp-content/uploads/2023/07/CCR-2017-corrected-per-OEPA.pdf>

2018 Corrected CCR: <https://www.lithopolis.org/wp-content/uploads/2023/07/CCR-2018-corrected-per-OEPA.pdf>

Public Notice:

Total Coliform: We are required to monitor your drinking water for specific contamination on a regular basis. Results of monitoring are an indicator of whether or not your drinking water meets health standards. During **June 2019 we did not monitor or test for total coliform bacteria** and during the **2020 Annual time period we did not monitor or test for disinfection byproducts** as required and therefore, cannot be sure of the quality of your drinking water during that time. This notice is only to inform you that we did not monitor and report results for the presence of the contaminants listed above during time periods listed, as required by Ohio EPA. You do not need to take any actions in response to this notice; you do not need to seek bottled water or boil your water. Upon being notified of these violations, the Village of Lithopolis was required to have the drinking water analyzed for the above-mentioned parameters and will take steps in the future to ensure that adequate testing will be conducted. Please share this information with others that may not receive this notice directly (i.e., schools, nursing homes, apartments, etc.)

Table of Detected Contaminants

Listed below is information on those contaminants that were found in the Village of Lithopolis drinking water.

Contaminants (Units)	MCLG	MCL	Level Found	Range of Detections	Violation	Sample Year	Typical Source of Contaminants
Residual Disinfectants							
Total Chlorine (ppm)	MRDLG 4	MRDL = 4	0.92	0.71-1.48	No	2022	Water additive used to control microbes
Lead and Copper							
Contaminant (units)	Action Level (AL)	MCLG	Individual Results over the AL	90% of test levels were less than	Violation	Sample Year	Typical source of Contaminants
Lead (ppb)	15 ppb	0	0	2.0	No	2022	Corrosion of household plumbing systems; Erosion of natural deposits.
	0 out of 10 samples were found to have lead levels in excess of the lead action level of 15 ppb.						
Copper (ppm)	1.3	1.3	0	0.148	No	2022	Corrosion of household plumbing systems; Erosion of natural deposits.
	0 out of 10 samples were found to have copper levels in excess of the copper action level of 1.3 ppm.						
Disinfectant and Disinfectant By-Products							
Contaminants (Units)	MCLG	MCL	Level Found	Range of Detections	Violation	Sample Year	Typical Source of Contaminants
Total Trihalomethanes (TTHM) (ppb)	N/A	80	20.0	4.7-20.0	No	2022	By-product of drinking water disinfection
Nitrate							
							Runoff from fertilizer use; leaching

Nitrate ppm	10	10	0.260 ppm	NA	No	2022	from septic tanks, sewage; Erosion of natural deposits
-------------	----	----	-----------	----	----	------	--

License to Operate (LTO) Status Information

In 2022 we had an unconditioned license to operate our water system.

Public Participation and Contact Information

Public participation and comment are encouraged at regular meetings of Lithopolis Village Council which meets the second and fourth Tuesday of each month at the Municipal Building, 11820 Lithopolis Road. For more information on your drinking water, contact Mayor Eric Sandine at the Municipal Office, or email at mayor@lithopolis.org. Or Ed VanVickle, Water Operator at 614-837-2031 or by email at wateroperator@lithopolis.org.

Definitions

- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant level (MCL): The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Parts per Million (ppm) or Milligrams per Liter (mg/L) are units of measure for concentration of a contaminant. A part per million corresponds to one second in a little over 11.5 days.
- Parts per Billion (ppb) or Micrograms per Liter (µg/L) are units of measure for concentration of a contaminant. A part per billion corresponds to one second in 31.7 years.
- The “<” symbol: A symbol which means less than. A result of <5 means that the lowest level that could be detected was 5 and the contaminant in that sample was not detected.

